

Infiltrator Corrugated Pipe HDPE Pipe Installation Instructions



Before You Begin

Infiltrator Corrugated Pipe Corr-A-Flex single wall and Corr-A-Flow dual wall HDPE pipe may only be installed according to State and/or local regulations. If unsure of the installation requirements for a particular site, contact the local building department.

The soil and site conditions must be approved prior to installation. Conduct a thorough site evaluation to determine proper sizing and siting of the system before installation. Unusual conditions may require additional investigations, including the recommendations of a qualified geotechnical or soils engineer.

RECEIVING AND UNLOADING

Upon arrival, the pipe should be inspected for potential damage due to shipment. Any damage should be noted on the delivery receipt and the supplier should be notified. While the pipe will withstand normal field handling, it should not be dropped from any appreciable height. Slings or strapping should not be removed before pipe is secured for unloading. Use tractors, forklifts, or construction equipment suitable for unloading with slings and chains rated for the weight of pipe.

STORAGE

BDC pipe is manufactured with an integral bell on one end. Since the bell wall is less stiff than the corrugated pipe profile, some deflection, or “flowering” of the bell may occur. The bell end will regain shape when the spigot end of the pipe is driven home and snapped into place. To prevent excessive “flowering” stacked pipe should be placed with the bell ends staggered, so the pipe is not laying directly on another piece of pipe or the ground.

Gasketing pipe for “silt tight” connections is covered with a protective wrap and should not be removed until the pipe is ready for lubrication and assembly.

Materials and Equipment Needed

- Corr-A-Flex Single Wall or Corr-A-Flow Dual Wall HDPE pipe
- Soil or silt tight joints
- Gaskets (if necessary)
- Backhoe
- Laser, Transit, or Level
- Shovel and Rake
- Tape Measure
- Screwdriver or Knife

SELECTING FOUNDATION, BEDDING AND BACKFILL MATERIAL

Pipe must be surrounded by compacted material in order to distribute vertical loads. Only native materials that meet class I, II, or III are acceptable. Sand, Silt or Clay mixtures (Class III) should not be used where water conditions can cause instability. Class II and III materials must be compacted. Please refer to Table 1 below for class definitions.

**Note: IVA is unacceptable material.*

Table 1: Foundation, Bedding, and Backfill Material Classes

ASTM D2321		ASTM D2487		Min. Compaction Required (%)
Class	Type	Notation	Description	
IA	Manufactured Aggregates: clean open-graded	N/A	Angular crushed stone or rock, gravel, coral, crushed slag, cinders or shells, large voids with little or no fines	Dumped
			Angular crushed stone or other Class IA material and stone/sand mixtures; little or no fines	
II	Coarse-Grained Soils; clean	GW	Well graded gravel, gravel / sand mixtures; little or no fines	85%
		GP	Poorly-graded gravel, gravel / sand mixtures; little or no fines	85%
		SW	Well graded sands, gravelly sands; little or no fines	85%
		SP	Poorly-graded sands, gravel sands; little or no fines	85%
		eg. GW-GC, SP-SM	Sand and gravels which are borderline between clean and with fines	85%
III	Coarse-grained soils with fines	GM	Silty, gravels, gravel/sand/silt mixtures	90%
		GC	Clayey gravels, gravel/sand/clay mixtures	90%
		SM	Silty sands, sand/silt mixtures	90%
		SC	Clayey sands, sand/clay mixtures	90%

Excavating and Preparing the Site

Note: Underlying pipe material must be uniform and provide resistance to load.

1. Stake out the location of the trench.
2. Excavate the trench to ensure walls are stable under all conditions. Trench width should be just large enough so that backfill can be compacted completely around the pipe. Use Table 2 below to determine trench depth and width.

Table 2: Minimum Trench Dimensions

Pipe Size	Min. Trench Depth	Min. Trench Width
3"	16-20"	8"
4"	17-21"	21"
6"	19-23"	23"
8"	22-26"	25"
10"	24-28"	28"
12"	26-30"	30"
15"	30-34"	34"
18"	34-38"	40"
24"	42-46"	50"

Note: Minimum width should be the pipes outside diameter plus 16 inches (400 mm), or pipe outside diameter times 1.25, plus 12 inches (300 mm) to allow working room for compaction equipment.

Note: For parallel pipes, allow 12 inches (300 mm) between pipes.

4. Remove any large stones and other debris. Do not use the bucket teeth to rake the trench bottom.

Note: If foundation material is soft, it must be removed to maintain grade. Remove for a depth of 2 feet (0.6 m) and replace with suitable compacted material.

5. Verify that each trench is level or has the prescribed slope per design or application using a level, transit or laser.

CONSTRUCTION LOADS

The pipe must be protected from equipment loads during construction. Heavy equipment should not be allowed near or over buried pipes. Extra cover may be required to support loads. For shallow installations, it may be necessary to mound fill material to provide proper minimum cover to handle the load. The mound can be removed after construction to achieve final grade. Table 3 below explains load covers needed.

Table 3: Minimum Cover for 12" - 24" Pipe Bearing Construction Loads

Axle Load, kips	Cover, in.
18.0 - 50.0	24.0
51.0 - 75.0	30.0
76.0 - 110.0	36.0
110.0 - 150.0	36.0

Installing the System

1. Lay and assemble pipe in trench per design. Pipe should be placed with the bell end pointed in the direction of the work progress.

2. Pipe must be securely surrounded by bedding material. Evenly compact bedding material on each side of the pipe. The haunch zone should be no more than 6 inches up to the spring line of the pipe. Ensure that the material is fully compacted without voids.

Note: Haunching should be completed as the pipe is installed.

Note: Bedding material should be free of large stones and be the same material as the backfill material.

3. Place initial backfill around pipe at least 6" (150 mm) above the crown of the pipe. Each layer must be compacted before the next lift is placed.

Note: Pipes laid in a parallel installation require the same backfill support.

Note: Backfill must be evenly compacted.

4. The final cover shall be 1' (300 mm) for 3"-24" (75-600 mm) pipe, measured from the crown of the pipe to final grade.

**LIMITED WARRANTY AND LIMITATION OF LIABILITY
PIPE PRODUCTS**

ISI Pipe, LLC does hereby warrant, subject to the limitations hereinafter stated, its PIPE PRODUCTS Pipe to be free from defects in material and workmanship under normal use and service for a period of twelve (12) months from the date of invoice. This limited warranty extends only to the original purchaser for use, and will be void if the product is used under conditions other than those for which it was designed or if it is not used in compliance with all instructions contained in any operating manual or specification sheets provided for such product and all applicable state and local codes.

The sole obligation of ISI Pipe, LLC, under this limited warranty, and the exclusive remedy of the purchaser under this limited warranty is the repair or replacement, without charge, F.O.B. shipping point, of such products or parts of products only, specifically excluding any labor or installation thereof, ISI Pipe, LLC, after inspection, determines to be defective.

Purchaser must notify ISI Pipe, LLC, in writing at its address shown below within ten (10) days from the date of discovery of any claimed defect specifically stating the details of such defect, and, if requested by ISI Pipe, LLC, return the defective product, freight prepaid, to ISI Pipe, LLC, F.O.B. shipping point as shown ISI Pipe, LLC's order acknowledgement.

ISI Pipe, LLC shall not be liable for any other damages, whether direct or consequential. Specifically, but without limitation, ISI Pipe, LLC shall not be liable for any crop damage or any other incidental or consequential damages resulting from any breach of warranty, express or implied, or from any defects in its products. SOME STATES DO NOT ALLOW THE EXCLUSION OR LIMITATION OF INCIDENTAL OR CONSEQUENTIAL DAMAGES, SO THIS LIMITATION OR EXCLUSION MAY NOT APPLY TO YOU. THIS WARRANTY GIVES YOU SPECIFIC LEGAL RIGHTS AND YOU MAY ALSO HAVE OTHER RIGHTS WHICH VARY FROM STATE TO STATE.

There are no understandings or undertakings of any kind with respect to the products or any part thereof which are not expressly set forth and contained herein, and all sales are made without any representation or warranty by ISI Pipe, LLC, that the goods are suitable for any particular purpose. In the event any provision of this LIMITED WARRANTY AND LIMITATION OF LIABILITY is held to be illegal or unenforceable by any court of competent jurisdiction, the remaining provisions shall remain in full force and effect.

LIMITED CLAIMS PERIOD: Any action for breach of this LIMITED WARRANTY AND LIMITATION OF LIABILITY must be commenced within one (1) year after the cause of action has accrued.

THERE ARE NO EXPRESS OR IMPLIED WARRANTIES BY ISI PIPE, LLC, OTHER THAN THOSE SPECIFICALLY SET OUT ABOVE. THERE ARE NO IMPLIED WARRANTIES OF MERCHANTABILITY OR OF FITNESS FOR A PARTICULAR PURPOSE IN CONNECTION WITH ANY SALE EXCEPT AS SET FORTH ABOVE.

No statement, remark, agreement, representation, promise or understanding, oral or written, made by ISI Pipe, LLC, or any agent, representative or employee thereof, which is not contained herein, will be recognized by, or be enforceable or binding upon ISI Pipe, LLC.

For more information go to www.infiltratorcorrugatedpipe.com



North Carolina

1030 Corporate Drive
Salisbury, NC 28144
(800) 448-4784

www.infiltratorcorrugatedpipe.com

Alabama

3 Downing Drive
Phenix City, AL 36867
(800) 438-4784

www.infiltratorcorrugatedpipe.com

Corporate Offices

6 Business Park Road • P.O. Box 768
Old Saybrook, CT 06475
860-577-7000 • FAX 860-577-7001

1-800-221-4436

www.infiltratorsystems.com

Distributed By: