



PARAMETER	UNITS U.S. [METRIC]	VALUE
INVERT HEIGHT	in [mm]	43.4 [1,102]
EFFECTIVE (TOTAL) CAPACITY	gal [L]	417 [1,577]
MANHOLE AREA	in ² [m ²]	432 [0.28]

1. TANK MARKINGS WILL INCLUDE: MANUFACTURER NAME, LIQUID CAPACITY, MANUFACTURE DATE, MAXIMUM BURIAL DEPTH, AND STATE DESIGNATED SERIAL NUMBER.
2. EXTERIOR OF MANHOLE COVER INCLUDES THE FOLLOWING WARNING: "DANGER DO NOT ENTER POISON GASES" WRITTEN IN ENGLISH, FRENCH, AND SPANISH.
3. MAXIMUM BURIAL DEPTH IS 48 IN [1,219 MM]
4. DIMENSIONS ON DRAWING SHOWN IN INCHES [MILLIMETERS].

INFILTRATOR SYSTEMS INC. 6 Business Park Rd., Old Saybrook, CT 06475 (800) 221-4436		
TW-375 PUMP TANK CONFIGURATION		
Drawn by: R.D.	DWG NO. 1	Date: 10-29-08
SCALE Not to Scale	Checked by: EPK	SHEET 1 of 1